

## **Stretch Code Energy Regulations**

Currently, the Massachusetts State Building Code uses the 2009 International Energy Conservation Code with some amendments to regulate energy use in projects that require a building permit. This regulation affects everything from lighting to boiler efficiency, but the meat of the regulation as it pertains to residential units is the thermal envelope. **In FCCIP towns, Ashfield, Buckland, Conway, Gill, Leverett, Rowe, and Shutesbury have adopted the STRETCH Energy Code.** There has been some confusion as to the requirements, especially for renovations and additions.

### **Stretch Code Requirements for New Construction (1-2 family):**

- Hire a Resnet Certified HERS Rater:  
<http://www.resnet.us/directory/auditor/01301/89/home-energy-raters-hers-raters/1>
- For units less than 3,000 sq. ft., a hers rating of 70 or less is required; for units >3,000 sq.ft., 65 or less.
- Demonstrate compliance with the [Energy Star Qualified Homes Thermal Bypass Inspection Checklist](#).

**Stretch Code Prescriptive Option for Additions (1-2 family):** In lieu of the above requirements, additions that comply with all of the following will comply with stretch energy code:

- Comply with IECC requirements for new construction (see above).
- Demonstrate compliance with the Energy Star Qualified Homes Thermal Bypass Inspection Checklist.
- Meet the fenestration [u-factor requirements as listed in Energy Star Program\(.30 max u value windows, etc.\)](#)
- Perform a post construction duct test for all ducts and air handlers located in **unconditioned space** to demonstrate leakage to outdoors of less than or equal to 4cfm per 100sq.ft. of conditioned floor area.

### **Stretch Code Prescriptive Option for Alterations, Renovations, and Repairs (1-2 family):**

- Whenever the building envelope is accessed, the affected portion of the envelope must comply with the prescriptive requirements for additions(see above).
- Envelope insulation must meet the minimum requirements of IECC 2009 **or** fully fill existing cavities with insulation that meets or exceeds an R value of **3.5** per inch.
- In lieu of the prescriptive requirements, a HERS rating of 80 or less for units >2000sq.ft. and 85 or less for units<2000sq.ft. will meet requirements.