

Electrical inspections are required for ALL installations, repairs and maintenance of electrical wiring and fixtures used for light, heat, power, signaling, communications, security and Fire alarm systems in all buildings and structures subject to the provisions of M.G.L. c 143.

#### Photovoltaic Systems (solar installations)

All PV installations require a Rough (rail bonding) and a final Electrical inspection.

#### Meter Reconnect

Where power has been disconnected for a period of Six (6) months or more local Inspection is required. Inspection may also be required by Utility at their discretion.

Below are requirements for Meter restoration:

1. Electrical permit SHALL be submitted by a Licensed Electrician. (Utility WR # required)
2. Upon completion of inspection/ repair of electrical system, electrician shall contact Electrical Inspector for approval.
3. After approval of work ,Electrical Inspector will contact Utility for Reconnection of Meter.

Electrical inspections will be completed upon request from the Licensed permit holder ONLY.

Electrical Permits WILL NOT be issued to non-licensed persons.

Electrical Permits WILL NOT be issued to homeowners.